



DR. S. MAUDGAL
DIRECTOR (IA)
Ph: 624837

SECRET

807

सार :
Telegram : PARIYAVARAN,
NEW DELHI
दूरभाष :
Telephone :
टेलिग्राम :
Telex : "31 5205 DOE IN"

भारत सरकार

पर्यावरण एवं वन मंत्रालय

पर्यावरण विभाग

GOVERNMENT OF INDIA
MINISTRY OF ENVIRONMENT & FORESTS
DEPARTMENT OF ENVIRONMENT

योगेश्वर हाउस, शाहजहाँ रोड,
Bikaner House, Shahjahan Road,
नई दिल्ली-110011,
New Delhi-110011.

December 4, 1986

FAX: Att. Dr. Abhiraj Singh
0522-2326696

D.O.No. 11018/13/85-IA

Dear Shri Rao,

The proposal for setting up two units of 235 MW each at Rawat-bhatta, Rajasthan has been examined and approved from the environmental angle subject to the effective implementation of the following:

- i. Pollution Control measures for air and water conform to the International Commission on Radiological Protection (ICRP) standards and surveillance undertaken on a regular basis by the Department of Atomic Energy. Monitoring mechanism for control of air and water quality, independent of the project authorities, will be made operational as a part of the project;
- ii. The impact of thermal pollution in the R.P. reservoir on aquatic life will be studied; within and outside the thermal wedge;
- iii. Effective precautionary measures would be enforced for the safe disposal of radio-active solid wastes. Measures for burying the solid wastes in concrete trenches and tile holes or more effective measures would be adopted; and
- iv. The emergency disaster plans, both on-site and off-site, will be detailed and tested on regular intervals.

It would be appreciated if the Department of Environment is kept apprised of the actions taken in regard to the above stipulations:

With regards,

Yours sincerely,

S. Maudgal

(S. MAUDGAL)

Shri S.N. Narasingha Rao,
Member-Secretary,
Nuclear Power Board,
Department of Energy,
Homibhabha Road,
Colaba, BOMBAY-400005.

(Environmental Clearance
for RAPP 3 & 4 Site)

Copy for information pl.

Shri K. P. Ojha

Site Director (RAPS 1 to 4)

S. P. M. P. ...

*airman
P.B./S.C.
any kindly
be
be
10/12/86*

85-02