

On January 11, 2017, RAPS Unit-4 tripped at 9.45 AM. Following the event, maintenance activities were being carried out, when in the afternoon at around 14:00 hrs, a maintenance team of four persons was exposed to a minor splash of hot water / steam from a valve in the feed water system.

They were promptly taken to hospital. After examination and first aid, they were sent back in the evening itself. They returned to work and there was no loss of mandays on account of this minor incident.